

FIRE ALARM PLAN REVIEW REQUIREMENTS

The following is the list of requirements for Fire Alarm Systems installed within the Town of Johnston. Both municipally connected and local fire alarm requirements are listed within this document.

Plan review cannot be completed until all required Fire Alarm System components, locations and existing equipment are submitted. All plans must be submitted with a completed "Fire Alarm Plan Review Application." Plans are to be submitted to the Fire Prevention Clerks office located at 1520 Atwood Ave. Johnston, RI 02919.

The following (but not limited to) must be submitted with plans:

- Plans - Four (4) sets of architectural drawings
- Plans must have Fire Alarm Legend
- Plans must be drawn to scale
- One (1) set of equipment cut sheets
- Candela ratings must be shown on floor plans.
- Wiring diagram must be included
- If a Municipal Radio Box is required, the installer is responsible for having the radio box installation certified by the manufacturer, prior to the final inspection.

All Fire Alarm Systems (including fire alarm systems that are not required by code) shall be installed per Rhode Island State Fire Safety Code Chapter 9, N.F.P.A. 101 and NFPA 72

KNOX BOXES: Key safe boxes are required on all buildings. Boxes can be ordered online at www.knoxbox.com, or by calling 1-800-552-5669. All key safe boxes shall be mounted at a height of sixty (60) inches above finished grade and nearest to Fire Alarm Control Panel as possible (contact the Fire Alarm Superintendent or Fire Marshal for the exact location).